



NOTE:

1. TOP OF VALVE BOX LIDS TO BE FLUSH WITH FINISHED SURFACE LEVEL IN LAWN AREAS. LID TO BE 50mm PROUD IN GARDEN AREAS.
2. ALL IRRIGATION COMPONENTS TO HAVE SWIVEL UNIONS ON EITHER SIDE.
3. MIN. 50mm CLEARANCE BETWEEN IRRIGATIONS COMPONENTS AND VALVE BOX IN ALL DIRECTIONS.

TAGS TO SHOW COMPONENT TYPE (EG 25mm PULSE METER) & ACTIVE CONTROLLER. LOCATION TO BE SHOWN IF THERE IS NO RELEVANT CONTROLLER. TAGS CONNECTED TO ITEM WITH ZIP TIES (S/S ABOVE GROUND, PLASTIC IN VALVE BOXES)

TYPICAL MAIN FILTER INSTALLATION  
ABOVE GROUND

DRAWING NOT TO SCALE

		SURVEY		DRAWN DJA	SIGNED A. PICKERING	DATE 17/03/15	DIRECTOR DEVELOPMENT SERVICES		SHEET 1 OF 1	
		SURVEY FILE No		DESIGNED AP	SIGNED A. PICKERING	DATE 16/04/15			WORKS JOB No. -	
A	ORIGINAL ISSUE	LEVEL DATUM		CHECKED -	SIGNED -	DATE -	ORIGINAL SIGNED BY GERARD CARLYON		DRAWING No.	
	DATE	DESCRIPTION		MANAGER PARKS & ENVIRONMENT			DATE		AMEND.	
		AMENDMENTS AND REVISIONS		ORIGINAL SIGNED BY PETER OWEN		20.5.15	DATE		A	
		MERIDIAN							A3-08417	
		STANDARD DRAWINGS/A3-08417							A	



STANDARD  
IRRIGATION  
MAIN FILTER - ABOVE GROUND

A3-08417