


TYPICAL ISOLATION VALVE INSTALLATION
(FOR MANUAL LATERAL ISOLATION)

NOTE:
THE HANDLE OF THE VALVE MUST MAINTAIN A MINIMUM 50mm CLEARANCE FROM VALVE BOX, GRAVEL LAYER AND OTHER IRRIGATION COMPONENTS IN ALL POSITIONS FROM FULLY SHUT TO FULLY OPEN

			SURVEY	DRAWN DJA	SIGNED A. PICKERING	DATE 17/03/15	DIRECTOR DEVELOPMENT SERVICES		STANDARD IRRIGATION ISOLATION VALVE FOR MANUAL LATERAL ISOLATION	SHEET 1 OF 1
			SURVEY FILE No	DESIGNED AP	SIGNED A. PICKERING	DATE 16/04/15	ORIGINAL SIGNED BY GERARD CARLYON		WORKS JOB No. -	
A		ORIGINAL ISSUE	LEVEL DATUM	CHECKED -	SIGNED -	DATE -	DATE 21/5/15		DRAWING No. A3-08420	AMEND. A
			AMENDMENTS AND REVISIONS	MANAGER PARKS & ENVIRONMENT						
			DATE	DESCRIPTION	APPVD	MERIDIAN	ORIGINAL SIGNED BY PETER OWEN	DATE 20.5.15		
			\\STANDARD DRAWINGS\A3-08420							