

Electrical information for stall holders

This information sheet is to provide information to stall holders to ensure compliance with electrical safety standards, particularly AS/NZS3002 and the QLD Electrical Safety Regulations.

- All leads used external to a site must be minimum heavy duty leads. Light duty or Medium/Ordinary duty is not suitable. The maximum permitted length of a lead is 15m.
- All electrical items must display a current in date test tag with a maximum duration of 6 months (12 months for double insulated items).
- Double adaptors and piggyback plugs are not permitted.
- All electrical items and leads must be protected from damage from objects, heat and liquids.
- Power boards are not suggested. If used, the following applies:
 - Power boards, including their lead and plug, must be located fully within the confines of the concession (gazebo, tent, stage, vehicle or trailer) and fully protected from the weather
 - Power boards must not be connected to each other
 - Power boards can only be used to supply low power equipment (no heating or cooling equipment)
 - Power boards shall be adequately supported by a rigid section of the concession structure. They are not permitted to be laid on the ground or other horizontal surface.
- Any item installed outside of a covered stall must have a minimum of IP33 rating.
- All connection points for leads and appliances must be:
 - Located within the confines of the concession under cover
 - Connected to an outlet with minimum IP33 rating
 - Covered by an appropriate manufactured connection cover with minimum IP33 rating
 - Be manufactured to provide a minimum IP33 rating
- No part of any item designed or market 'for home or office use', 'indoor use' or be marked with a 'house symbol' is permitted to be located outside the confines of the concession fully protected from the weather.
- Electrical equipment shall not be located within 1.5m horizontally or 0.5m vertically from gas cylinders.
- All items to be used in accordance with manufacturers instruction.