


NOTE:

1. ALL COMPONENTS CAN BE INSTALLED IN ONE BOX IF MINIMUM CLEARANCES ARE PROVIDED
2. LID TO BE FLUSH WITH GROUND IN LAWN AREAS. LID TO BE 50mm PROUD IN GARDEN AREAS
3. MIN. 50mm CLEARANCE BETWEEN IRRIGATION COMPONENTS AND VALVE BOX IN ALL DIRECTIONS

**TYPICAL PRESSURE REDUCING VALVE INSTALLATION
FOR MANUAL DRIP AND MICRO SYSTEMS**

DRAWING NOT TO SCALE

		SURVEY		DRAWN DJA	SIGNED A. PICKERING	DATE 17/03/15	DIRECTOR DEVELOPMENT SERVICES				SHEET 1 OF 1	
		SURVEY FILE No		DESIGNED AP	SIGNED A. PICKERING	DATE 16/04/15	ORIGINAL SIGNED BY GERARD CARLYON				WORKS JOB No.	
A	ORIGINAL ISSUE	LEVEL DATUM		CHECKED -	SIGNED -	DATE -	DATE 21/5/15		DRAWING No.		AMEND.	
DATE		DESCRIPTION		MANAGER PARKS & ENVIRONMENT		DATE		A3-08422		A		
AMENDMENTS AND REVISIONS		MERIDIAN		ORIGINAL SIGNED BY PETER OWEN		DATE		A3-08422		A		
\STANDARD DRAWINGS\A3-08422												

**STANDARD
IRRIGATION
PRESSURE REDUCING VALVE
(MANUAL VALVES)**