



NOTES:

1. ALL DIMENSIONS IN MILLIMETRES UNLESS NOTED OTHERWISE
2. ENCLOSURE TO BE 3 POINT LOCKING, STAINLESS STEEL PROPRIETARY 'MONARCH' UNIT MANUFACTURED BY 'B & R ENCLOSURES', WITH STAINLESS STEEL PADLOCKABLE SWING HANDLE OR APPROVED EQUIVALENT. DIMENSIONS AND SELECTION OF ENCLOSURE TO SUIT FUNCTIONAL REQUIREMENTS AND TO PROVIDE NOMINAL CLEARANCE 50 CLEARANCE TO FRONT FACE AND OUTER SIDES OF INTERNALLY MOUNTED ELECTRICAL SWITCHBOARD / IRRIGATION CONTROLLER.
3. SWITCHBOARD TO INCLUDE MINIMUM 25% SPARE CAPACITY UNLESS STATED OTHERWISE.
4. WIDTH BETWEEN POSTS TO SUIT THE WIDTH OF ENCLOSURE +10.
5. FOOTING CONCRETE TO BE N25 IN ACCORDANCE WITH AS1379 & AS3600.
6. ALL UNDERGROUND CABLES AND CONDUITS TO BE INSTALLED IN ACCORDANCE WITH AS3000.
7. ELECTRICAL PIT MINIMUM SIZE NUMBER 4. PIT TO BE INSTALLED TO TRANSPORT AND MAIN ROADS STANDARDS.
8. ALL STEEL COMPONENTS TO BE 316 GRADE STAINLESS STEEL.

C	05.2020	NOTES AND DIMENSIONS ADDED	JC	
B	22.01.15	STEEL PLATE SIZE CORRECTED		
A	15.08.14	ORIGINAL ISSUE		
DATE		DESCRIPTION	APPVD	
AMENDMENTS AND REVISIONS				
ISTANDARD DRAWINGS\IRRIGATION\A3-00906.DWG				

SURVEY	DRAWN R.MILES	SIGNED R.MILES	DATE 15.08.14
SURVEY FILE No	DESIGNED G.TAYLOR	SIGNED G.TAYLOR	DATE 18.08.14
LEVEL DATUM	CHECKED W.WEST	SIGNED W.WEST	DATE 18.08.14
MERIDIAN	MANAGER TECHNICAL SERVICES		
	ORIGINAL SIGNED BY G.HAWES	DATE 18.08.14	DATE 18.08.14
			RPEQ 5693

DIRECTOR ENGINEERING AND COMMERCIAL INFRASTRUCTURE	ORIGINAL SIGNED BY JASON DEVITT
DATE 20.08.14	



STANDARD  
RAISED ELECTRICAL SWITCHBOARD  
&  
IRRIGATION CONTROLLER ENCLOSURE

SHEET 1 OF 1	
WORKS JOB No.	
DRAWING No.	AMEND.
A3-00906	C