


**NOTES:**

1. DRIP PIPE TO BE INSTALLED ON SOIL SURFACE AND COVERED WITH 100mm MULCH
2. DRIP PIPE TO BE HELD IN PLACE IN GARDENS WITH STAKES AT MIN. 3 METRE INTERVALS AND AT ALL FITTINGS
3. DRIP PIPE TO BE INSTALLED 100mm BELOW FINISHED SURFACE LEVEL IN LAWN AREAS
4. CLOSEST DRIP LINE TO EDGE OF IRRIGATION AREA TO BE MAX 200mm FROM EDGE
5. THE TOTAL LENGTH OF ALL INTERCONNECTED DRIP LINE SHALL NOT EXCEED THE MAXIMUM RUN LENGTH
6. LDPE TO DRIP CONNECTORS TO BE MULTI BARBED WITH STAINLESS STEEL CLIPS

DRAWING NOT TO SCALE

**TYPICAL SUBSURFACE DRIP SYSTEM INSTALLATION**

		SURVEY		DRAWN DJA	SIGNED A. PICKERING	DATE 17/03/15	DIRECTOR DEVELOPMENT SERVICES		SHEET 1 OF 1	
		SURVEY FILE No		DESIGNED AP	SIGNED A. PICKERING	DATE 16/04/15			WORKS JOB No. -	
A	ORIGINAL ISSUE	LEVEL DATUM		CHECKED -	SIGNED -	DATE -			DRAWING No. A3-08432	
DATE	DESCRIPTION	APPVD	MANAGER PARKS & ENVIRONMENT		ORIGINAL SIGNED BY PETER OWEN		DATE 20.5.15	<p><b>STANDARD IRRIGATION SUBSURFACE DRIP SYSTEM</b></p>		
AMENDMENTS AND REVISIONS			MERIDIAN		ORIGINAL SIGNED BY PETER OWEN		DATE 21/5/15			
\STANDARD DRAWINGS\A3-08432										