



TYPICAL SOLENOID VALVE INSTALLATION  
(FOR SPRINKLERS WITHOUT MAINLINE FILTER)

NOTE:

1. ALL COMPONENTS CAN BE INSTALLED IN ONE BOX IF MINIMUM CLEARANCES ARE PROVIDED.
2. MIN. 50mm CLEARANCE BETWEEN IRRIGATION COMPONENTS AND VALVE BOX IN ALL DIRECTIONS
3. LID TO BE FLUSH WITH FINISHED SURFACE LEVEL IN LAWN AREAS. LID TO BE 50mm PROUD IN GARDEN AREAS.

DRAWING NOT TO SCALE

		SURVEY		DRAWN DJA	SIGNED A. PICKERING	DATE 17/03/15	DIRECTOR DEVELOPMENT SERVICES		STANDARD IRRIGATION SOLENOID VALVE FOR SPRINKLERS WITHOUT MAINLINE FILTER		SHEET 1 OF 1	
		SURVEY FILE No		DESIGNED AP	SIGNED A. PICKERING	DATE 16/04/15	ORIGINAL SIGNED BY GERARD CARLYON		WORKS JOB No.		-	
A	ORIGINAL ISSUE	LEVEL DATUM		CHECKED -	SIGNED -	DATE -	DATE 21/5/15		DRAWING No.		AMEND.	
DATE	DESCRIPTION	MERIDIAN		MANAGER PARKS & ENVIRONMENT		DATE	21/5/15		A3-08424		A	
AMENDMENTS AND REVISIONS				ORIGINAL SIGNED BY PETER OWEN		DATE						
\STANDARD DRAWINGS\A3-08424												