



NOTE:

1. ALL COMPONENTS CAN BE INSTALLED IN ONE BOX IF MINIMUM CLEARANCES ARE PROVIDED
2. MIN. 50mm CLEARANCE BETWEEN IRRIGATION COMPONENTS AND VALVE BOX IN ALL DIRECTIONS.
3. LID TO BE FLUSH WITH FINISHED SURFACE LEVEL IN LAWN AREAS. LID TO BE 50mm PROUD IN GARDEN AREAS

TYPICAL DRIP SYSTEM SOLENOID VALVE INSTALLATION

DRAWING NOT TO SCALE

		SURVEY		DRAWN DJA	SIGNED A. PICKERING	DATE 17/03/15	DIRECTOR DEVELOPMENT SERVICES		SHEET 1 OF 1	
		SURVEY FILE No		DESIGNED AP	SIGNED A. PICKERING	DATE 16/04/15			WORKS JOB No. -	
A	ORIGINAL ISSUE	LEVEL DATUM		CHECKED -	SIGNED -	DATE -	ORIGINAL SIGNED BY GERARD CARLYON		DRAWING No.	
DATE	DESCRIPTION	APPVD	MERIDIAN		MANAGER PARKS & ENVIRONMENT		DATE 21/5/15		AMEND.	
AMENDMENTS AND REVISIONS			ORIGINAL SIGNED BY PETER OWEN		DATE 20.5.15		DATE 21/5/15		A3-08425	
\STANDARD DRAWINGS\A3-08425									A	



STANDARD
IRRIGATION
DRIP SYSTEM SOLENOID VALVE